

# Certificate



SIL/PL  
Capability

www.tuv.com  
ID 060000000

**No.: 968/V 1158.01/20**

<b>Product tested</b>	Ball Valves with Pneumatic Turn Actuators	<b>Certificate holder</b>	G. Bee GmbH Robert-Bosch-Straße 14 71691 Freiberg a.N. Germany
<b>Type designation</b>	Ball Valves: 71MS/71ME, 75, 77, 79S/79E, 87S/87E, 168S/168E, 964 Pneumatic Actuators: DAE / GTE (single acting), DAD / GTD (double acting)		
<b>Codes and standards</b>	IEC 61508 Parts 1-2 and 4-7:2010		
<b>Intended application</b>	Safety function: Ball valves: Safe closing or opening through auxiliary energy  Pneumatic actuators: Single acting: Move to the fail-safe position using spring force accumulator / auxiliary stored energy Double acting: Move to the fail-safe position using pneumatic air / auxiliary energy supply  The products are suitable for use in a safety instrumented system up to SIL 2 (low demand mode) and SIL 1 (high demand mode of operation). Under consideration of the minimum required hardware fault tolerance HFT = 1 the products may be used in a redundant architecture up to SIL 3.		
<b>Specific requirements</b>	The instructions of the associated Installation and Operating Manual shall be considered.		

Summary of test results see back side of this certificate.

Valid until 2025-04-17


The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/V 1158.01/20 dated 2020-06-22.

This certificate is valid only for products which are identical with the product tested.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2020-06-22

Certification Body Safety & Security for Automation & Grid

  
Dipl.-Ing. Gebhard Bouwer

**Holder:** G. Bee GmbH  
Robert-Bosch-Straße 14  
71691 Freiberg a. N.  
Germany

**Product tested:** Ball valves  
Types: 71MS / 71ME, 75, 77, 79S / 79E, 87S / 87E,  
168S / 168E, 964

**Results of Assessment**

Route of Assessment		2 <sub>H</sub> / 1 <sub>S</sub>
Type of Sub-system		Type A
Mode of Operation		Low Demand Mode
Hardware Fault Tolerance	HFT	0
Systematic Capability		<b>SC 3</b>

**Safe closing through axiliary energy**

Dangerous Failure Rate	$\lambda_D$	2.02 E-07 / h	<b>202 FIT</b>
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	8.85 E-04	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	8.94 E-05	

**Safe opening through auxiliary energy**

Dangerous Failure Rate	$\lambda_D$	1.25 E-07 / h	<b>125 FIT</b>
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	5.48 E-04	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	5.51 E-05	

Assumptions for the calculations above: DC = 0 %,  $T_1 = 1$  year,  $\beta_{1oo2} = 10$  %

**Origin of failure rates**

The stated failure rates for low demand are the result of an FMEDA with tailored failure rates for the design and manufacturing process.

The stated failure rates for high demand are the result of tests over the whole temperature range. If the conditions vary widely from the test conditions the failure rates might be adjusted.

Furthermore the results have been verified by qualification tests and field-feedback data of the last years (since the last evaluation).

Failure rates include failures that occur at a random point in time and are due to degradation mechanisms such as ageing.

The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

**Periodic Tests and Maintenance**

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.

**High demand Mode** <sup>(see note)</sup>

*for complete system (valve, actuator, solenoids)*

$B_{10d}$		45,326
Maximum Demands per Year	$n_{op}$	400 / a
<b>Average Frequency of a dangerous Failure per Hour</b>	<b>PFH</b>	<b>1.01 E-07</b>

**Note:** PFH has to be verified by the end user with the correct demand rate for the certain application.

The resulting PFH shall not be lower than 10 FIT. If the PFH calculation results in a lower value, 10 FIT shall be used for further investigation.

**Holder:** G. Bee GmbH  
Robert-Bosch-Straße 14  
71691 Freiberg a. N.  
Germany

**Product tested:** Pneumatic actuator - single-acting  
Type: DAE / GTE

### Results of Assessment

Route of Assessment		$2_H / 1_S$
Type of Sub-system		Type A
Mode of Operation		Low Demand Mode
Hardware Fault Tolerance	HFT	0
Systematic Capability		<b>SC 3</b>

### Move to the fail-safe position using spring force accumulator / auxiliary stored energy

Dangerous Failure Rate	$\lambda_D$	1.87 E-07 / h	<b>187 FIT</b>
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	8.19 E-04	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	8.27 E-05	

Assumptions for the calculations above: DC = 0 %,  $T_1 = 1$  year,  $\beta_{1oo2} = 10$  %

### Origin of failure rates

The stated failure rates for low demand are the result of an FMEDA with tailored failure rates for the design and manufacturing process.

The stated failure rates for high demand are the result of tests over the whole temperature range. If the conditions vary widely from the test conditions the failure rates might be adjusted.

Furthermore the results have been verified by qualification tests and field-feedback data of the last years (since the last evaluation)..

Failure rates include failures that occur at a random point in time and are due to degradation mechanisms such as ageing.

The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

### Periodic Tests and Maintenance

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.

### High demand Mode <sup>(see note)</sup>

*for complete system (valve, actuator, solenoids)*

$B_{10d}$		45,326
Maximum Demands per Year	$n_{op}$	400 / a
<b>Average Frequency of a dangerous Failure per Hour</b>	<b>PFH</b>	<b>1.01 E-07</b>

**Note:** PFH has to be verified by the end user with the correct demand rate for the certain application.

The resulting PFH shall not be lower than 10 FIT. If the PFH calculation results in a lower value, 10 FIT shall be used for further investigation.

**Holder:** G. Bee GmbH  
Robert-Bosch-Straße 14  
71691 Freiberg a. N.  
Germany

**Product tested:** Pneumatic actuator - double-acting  
Type: DAD / GTD

### Results of Assessment

Route of Assessment		$2_H / 1_S$
Type of Sub-system		Type A
Mode of Operation		Low Demand Mode
Hardware Fault Tolerance	HFT	0
Systematic Capability		<b>SC 3</b>

### Move to the fail-safe position using pneumatic air / auxiliary energy supply

Dangerous Failure Rate	$\lambda_D$	3.56 E-07 / h	<b>356 FIT</b>
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	1.56 E-03	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	1.59 E-04	

Assumptions for the calculations above: DC = 0 %,  $T_1 = 1$  year,  $\beta_{1oo2} = 10$  %

### Origin of failure rates

The stated failure rates for low demand are the result of an FMEDA with tailored failure rates for the design and manufacturing process.

The stated failure rates for high demand are the result of tests over the whole temperature range. If the conditions vary widely from the test conditions the failure rates might be adjusted.

Furthermore the results have been verified by qualification tests and field-feedback data of the last years (since the last evaluation)..

Failure rates include failures that occur at a random point in time and are due to degradation mechanisms such as ageing.

The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

### Periodic Tests and Maintenance

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.

### High demand Mode <sup>(see note)</sup>

*for complete system (valve, actuator, solenoids)*

$B_{10d}$		45,326	
Maximum Demands per Year	$n_{op}$	400 / a	4,57 E-02 / h
<b>Average Frequency of a dangerous Failure per Hour</b>	<b>PFH</b>	<b>1.01 E-07</b>	

**Note:** PFH has to be verified by the end user with the correct demand rate for the certain application.

The resulting PFH shall not be lower than 10 FIT. If the PFH calculation results in a lower value, 10 FIT shall be used for further investigation.